

Luminaire Schedule	
Symbol	
□	

Footcandles calculated using predicted lumen values after 50K hours of operation					
Label	Units	Avg	Max	Min	Avg/Min
Elec. Workplane	Fc	37.00	48	26	1.42
Office Workplane	Fc	32.88	42	23	1.43
Open Workplane	Fc	45.11	83	14	3.22
Receiving Workplane	Fc	39.04	48	26	1.50

Room Reflectance: 80-50-20%

40 fixtures of these 2x4 fixtures will be -CMA (w/EB as required)

