


75 fixtures of these 2x4 fixtures are -CMA (w/EB as required).



Room Reflectance: 80-50-20%

Footcandles calculated using predicted lumen values after 50K hours of operation

Label	Units	Avg	Max	Min	Avg/Min	Max/Min
A115 Workplane	Fc	57.49	75	31	1.85	2.42
A151 Workplane	Fc	35.75	50	21	1.70	2.38
A152 Workplane	Fc	63.76	87	30	2.13	2.90
A153 Workplane	Fc	46.78	60	28	1.67	2.14
Admin_C101_Workplane	Fc	51.70	60	31	1.67	1.94
Break_A109_Workplane	Fc	50.33	70	24	2.10	2.92
Classroom_A146_Workplane	Fc	51.78	64	28	1.85	2.29
Classroom_C120_Workplane	Fc	60.08	83	31	1.94	2.68
Conference_A103_Workplane	Fc	68.49	94	20	3.42	4.70
Conference_A116_Workplane	Fc	54.41	70	29	1.88	2.41
CopyRm_A107_Workplane	Fc	51.87	68	27	1.92	2.52
Corridor-D102_Workplane	Fc	33.57	44	25	1.34	1.76
Corridor_H200_Workplane	Fc	34.23	46	18	1.90	2.56
Internal_A101_Workplane	Fc	53.24	72	24	2.22	3.00
Lobby_C100_Workplane	Fc	34.43	52	16	2.15	3.25
Mens_Workplane	Fc	36.33	58	13	2.79	4.46
Office_A101a_Workplane	Fc	52.44	63	36	1.46	1.75
Office_A102_Workplane	Fc	70.50	90	43	1.64	2.09
Office_A111a_Workplane	Fc	56.69	69	37	1.53	1.86
Office_A111b_Workplane	Fc	53.90	68	31	1.74	2.19
Office_A118_Workplane	Fc	59.67	79	18	3.32	4.39
Office_C104_Workplane	Fc	52.65	66	29	1.82	2.28
Office_C105_Workplane	Fc	56.69	68	42	1.35	1.62
Office_C106_Workplane	Fc	43.94	55	29	1.52	1.90
Open_H212_Workplane	Fc	77.56	115	25	3.10	4.60
Reception_A112_Workplane	Fc	65.72	91	29	2.27	3.14
Recruit_C106_Workplane	Fc	36.48	47	23	1.59	2.04
Space_H203_Workplane	Fc	46.88	59	27	1.74	2.19
Staff_A117_Workplane	Fc	42.78	51	28	1.53	1.82
Stock_B102_Workplane	Fc	54.45	70	19	2.87	3.68
Ullis_D107_Workplane	Fc	52.83	64	25	2.11	2.56
Women_Workplane	Fc	35.80	57	17	2.11	3.35
Workstation_A100_Workplane	Fc	61.11	85	17	3.59	5.00

