

STATE OF HAWAII
DEPARTMENT OF DEFENSE
OFFICE OF THE ADJUTANT GENERAL
3949 DIAMOND HEAD ROAD
HONOLULU, HAWAII 96816-4495

August 8, 2018

ADDENDUM NO. 1

High Expansion Foam System Services at JBPHH, Hawaii, State of Hawaii,
Department of Defense, Hawaii Air National Guard,
Job No. CA-1812

The items listed hereinafter are hereby made a part of the contract for the above mentioned project and shall govern the work taking precedence over previously issued contract documents governing the items mentioned. Receipt of this addendum is to be acknowledged on page OF-5 of the proposer's packet.

**THE BID OPENING DATE HAS BEEN CHANGED TO
AUGUST 15, 2018 AT 2:00PM**

The following are answers to questions submitted.

1. Section 3.2 describes the services to be performed on the HEF system(s), not to include the Fire Alarm System. However, table 2-1 contradicts this statement as it requires maintenance/inspection of Fire Alarm systems and devices. Can we clarify that the maintenance/inspection will ONLY be required to system/devices that affect the HEF system? Example, HEF Monitoring Panel that is integrated with the Fire Alarm System, pull stations, flow switches, tamper switches, solenoids, monitoring modules, heat detectors, sounding devices, and visual devices.
 - a. *The SOW calls to do the table 2.1 tasks as they apply to the HEF system only. The intent of this project is United Facility Criteria (UFC) compliance on HEF systems ONLY, UFC table 2.1 combine elements for the alarm system hence the note. Alarm fire system elements are NOT to be included.*

2. Also, B3408 has an integrated air monitoring system for the bays that the HEF Fire Alarm system is tied to. Will this be a part of the PWS, as part of the test and inspection of functionality? This system is not monitored by the HEF System, only integrated for air shut down.
 - a. *It is not included in the SOW so inspection or maintenance of it is NOT required.*

Arthur J. Logan
Major General
Adjutant General

Posted: August 8, 2018